

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

Certificate of constancy of performance

0761 – CPR – 0830

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

Fire and smoke protection doors, designed as steel sliding doors or steel lifting doors type "ORPHEUS-II" or "APOLLO-II"

produced by or for

Jansen Tore GmbH & Co. KG
Am Wattberg 51
26903 Surwold
Germany

in the manufacturing plant

Surwold (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034:2014 in connection with EN 13241:2003+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate has an annex with three pages. It has first been issued on 2020-01-15. It will remain valid till 2025-01-14, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2020-11-18

Z-3/1427/17



Dr.-Ing. W. Hinrichs
Head of certification

Intended use and essential characteristics according to EN 13501-2:2016 of the steel sliding door type "ORPHEUS-II" or steel lifting door type "APOLLO-II"

If the room is divided into fire and/or smoke sections
and/or in escape routes

Use of single-leaf, one-piece sliding door „ORPHEUS-II“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI₁ 15 / EI₁ 20 / EI₁ 30

EI₂ 15 / EI₂ 20 / EI₂ 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a / S₂₀₀

Use single-leaf, three-part telescopic sliding door „ORPHEUS-II“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI₁ 15

EI₂ 15 / EI₂ 20 / EI₂ 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a

Use double-leaf, one-piece sliding door „ORPHEUS-II“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI₁ 15 / EI₁ 20 / EI₁ 30

EI₂ 15 / EI₂ 20 / EI₂ 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a / S₂₀₀

Use two-leaf, three-part telescopic sliding door „ORPHEUS-II“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI₁ 15

EI₂ 15 / EI₂ 20 / EI₂ 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a

Use single-leaf, one-piece lifting gate „APOLLO-II“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI₁ 15 / EI₁ 20 / EI₁ 30

EI₂ 15 / EI₂ 20 / EI₂ 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a / S₂₀₀

Annex 3/3 to the certificate of constancy of performance No. 0761 – CPR – 0830

Use single-leaf wicket door:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / **E 30**

El₁ 15 / El₁ 20 / **El₁ 30**

El₂ 15 / El₂ 20 / **El₂ 30**

EW 20 / **EW 30**

C / C0 / C1 / C2 / C3 / C4 / **C5**

S_a / S₂₀₀

Basis:

Classification report No.: K-2202/073/19-MPA BS of 2020-09-11

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

Certificate of constancy of performance

0761 – CPR – 0831

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

**Steel sliding door or steel lifting door with fire protection properties
with the trade names 'ORPHEUS-IV' or 'APOLLO-IV'**

produced by or for

**Jansen Tore GmbH & Co. KG
Am Wattberg 51
26903 Surwold
Germany**

in the manufacturing plant

Surwold (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034:2014 in connection with EN 13241:2003+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate has an annex with three pages. It has first been issued on 2020-01-15. It will remain valid till 2025-01-14, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2021-02-17

Z-3/1427/17



Dr.-Ing. W. Hinrichs
Head of certification

Intended use and essential characteristics according to EN 13501-2:2016 of the steel sliding door "ORPHEUS-IV" or steel lifting door "APOLLO-IV"

If the room is divided into fire and/or smoke sections and/or in escape routes

Use of single-leaf, one-piece sliding door „ORPHEUS-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**
 EI₁ 15 / EI₁ 20 / EI₁ 30 / EI₁ 45 / **EI₁ 60**
 EI₂ 15 / EI₂ 20 / EI₂ 30 / EI₂ 45 / EI₂ 60 / **EI₂ 90**
 EW 20 / EW 30 / EW 60 / **EW 90**
 C / C0 / C1 / **C2**
S_a / S₂₀₀

Use single-leaf, three-part telescopic sliding door „ORPHEUS-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**
 EI₁ 15 / EI₁ 20 / EI₁ 30 / **EI₁ 45**
 EI₂ 15 / EI₂ 20 / EI₂ 30 / EI₂ 45 / EI₂ 60 / **EI₂ 90**
 EW 20 / EW 30 / EW 60 / **EW 90**
 C / C0 / C1 / **C2**
S_a

Use double-leaf, one-piece sliding door „ORPHEUS-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**
 EI₁ 15 / EI₁ 20 / **EI₁ 30**
 EI₂ 15 / EI₂ 20 / EI₂ 30 / EI₂ 45 / EI₂ 60 / **EI₂ 90**
 EW 20 / EW 30 / EW 60 / **EW 90**
 C / C0 / C1 / **C2**
S_a / S₂₀₀

Use two-leaf, three-part telescopic sliding door „ORPHEUS-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**

El₁ 15 / El₁ 20 / **El₁ 30**

El₂ 15 / El₂ 20 / El₂ 30 / El₂ 45 / El₂ 60 / **El₂ 90**

EW 20 / EW 30 / EW 60 / **EW 90**

C / C0 / C1 / **C2**

S_a

Use single-leaf, one-piece lifting gate „APOLLO-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**

El₁ 15 / El₁ 20 / El₁ 30 / El₁ 45 / **El₁ 60**

El₂ 15 / El₂ 20 / El₂ 30 / El₂ 45 / El₂ 60 / **El₂ 90**

EW 20 / EW 30 / EW 60 / **EW 90**

C / C0 / C1 / **C2**

S_a / S₂₀₀

Use single-leaf, three-part telescopic lifting gate „APOLLO-IV“:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**

El₁ 15 / El₁ 20 / El₁ 30 / El₁ 45 / **El₁ 60**

El₂ 15 / El₂ 20 / El₂ 30 / El₂ 45 / El₂ 60 / **El₂ 90**

EW 20 / EW 30 / EW 60 / **EW 90**

C / C0 / C1 / **C2**

S_a

Annex 3/3 to the certificate of constancy of performance No. 0761-CPR-0831

Use single-leaf wicket door:

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30 / E 45 / E 60 / E 90
EI₁ 15 / EI₁ 20 / EI₁ 30 / EI₁ 45 / EI₁ 60
EI₂ 15 / EI₂ 20 / EI₂ 30 / EI₂ 45 / EI₂ 60 / EI₂ 90
EW 20 / EW 30 / EW 60 / EW 90
C / C0 / C1 / C2 / C3 / C4 / C5
S_a / S₂₀₀

----- End of the certificate of constancy of performance -----